



CERTIFICATE

of Product Conformity (QAL1)

Certificate No.: 0000074630_00

AMS designation: MT100 for velocity

Manufacturer: Fluid Components International LLC

> La Costa Meadows Drive 1755 92078 San Marcos, California

Test Laboratory: TÜV Rheinland Energy GmbH

> This is to certify that the AMS has been tested according to the standards EN 15267-1 (2009), EN 15267-2 (2009), EN 15267-3 (2007) EN 16911 (2013) and EN 14181 (2015).

Certification is awarded in respect of the conditions stated in this certificate (this certificate contains 6 pages).



Publication in the German Federal Gazette

German Federal Environment Agency Dessau, 03 September 2021

i. A. Dr. Marcel Langner Head of Section II 4.1

Mad 4

(BAnz) of 05 August 2021

This certificate will expire on: 04 August 2026

Suitability Tested

www.tuv.com

ID 0000074630

EN 15267 **QAL1** Certified Regular Surveillance

TÜV Rheinland Energy GmbH Cologne, 02 September 2021

D. Rek Wis

ppa. Dr. Peter Wilbring

www.umwelt-tuv.eu

Phone: + 49 221 806-5200

tre@umwelt-tuv.eu

TÜV Rheinland Energy GmbH

Am Grauen Stein 51105 Köln

Test institute accredited to EN ISO/IEC 17025 by DAkkS (German Accreditation Body). This accreditation is limited to the accreditation scope defined in the enclosure to certificate D-PL-11120-02-00.



Certificate:

0000074630_00 / 03 September 2021



Test Report:

936/21247922/A of 11 February 2021

Expiry date:

04 August 2026

Publication:

BAnz AT 05.08.2021 B5, chap. I No. 1.1

Approved application

The tested AMS is suitable for use at combustion plants according to Directive 2010/75/EU, chapter III (13th BlmSchV), chapter IV (17th BlmSchV), 30th BlmSchV, 44th BlmSchV, plants in compliance with TA Luft and plants according to the 27th BlmSchV. The measured ranges have been selected so as to ensure as broad a field of application as possible.

The suitability of the AMS for this application was assessed on the basis of a laboratory test and a three-months field test at a municipal waste incinerator.

The AMS is approved for an ambient temperature range of -20 °C to +50 °C.

The notification of suitability of the AMS, performance testing and the uncertainty calculation have been effected on the basis of the regulations applicable at the time of testing. As changes in legal provisions are possible, any potential user should ensure that this AMS is suitable for monitoring the velocities relevant to the application.

Any potential user should ensure, in consultation with the manufacturer, that this AMS is suitable for the intended purpose.

Basis of the certification

This certification is based on:

- Test report 936/21247922/A of 11 February 2021 by TÜV Rheinland Energy GmbH
- Suitability announced by the German Federal Environment Agency (UBA) as the relevant body
- The ongoing surveillance of the product and the manufacturing process



Certificate:

0000074630_00 / 03 September 2021



Publication in the German Federal Gazette: BAnz AT 05.08.2021 B5, chap. I No. 1.1, UBA announcement dated 29 June 2021:

AMS designation:

MT100 for velocity

Manufacturer:

Fluid Components International LLC., San Marcos, USA

Field of application:

For plants requiring official approval and for plants according to the 27th BImSchV

Measuring ranges during performance testing:

| Component | Certification range | Unit |
|-----------|---------------------|------|
| Velocity | 0 – 30 | m/s |

Software version:

3.08M

Restriction:

The instrument is only fit for purpose in waste gas which is not saturated with water vapour.

Note:

The maintenance interval is four weeks.

Test Report:

TÜV Rheinland Energy GmbH, Cologne

Report no.: 936/21247922/A of 11 February 2021



Certificate: 0000074630_00 / 03 September 2021



Certified product

This certification applies to automated measurement systems conforming to the following description:

The AMS tested here consists of one or more measuring probes, in which one heated and one unheated sensor is installed per probe, as well as the electronics / control unit. The individual signals of the measuring probes (up to eight) result in an output signal that represents the total flow. The number of measuring probes results from the dimensions of the flue gas ducts where the probes are to be installed later and the volume flow determined.

During the performance test, 2 control units with two measuring probes each were used. Through this potential combination of the number of probes and sensors, the smallest possible number of measuring probes was tested and, in addition, a practice-oriented distribution of the sampling points is possible. For each control unit up to four measuring probes can be installed.

The software version 3.08M has not changed over the entire audit period.

The AMS tested here comprises the following components:

- Electronic / control unit
- Two measuring probes, length during the performance test 533 mm each



Certificate: 0000074630_00 / 03 September 2021



General remarks

This certificate is based upon the equipment tested. The manufacturer is responsible for ensuring that on-going production complies with the requirements of the EN 15267. The manufacturer is required to maintain an approved quality management system controlling the manufacturing process for the certified product. Both the product and the quality management systems shall be subject to regular surveillance.

If a product of the current production does not conform to the certified product, TÜV Rheinland Energy GmbH must be notified at the address given on page 1.

A certification mark with an ID-Number that is specific to the certified product is presented on page 1 of this certificate.

This document as well as the certification mark remains property of TÜV Rheinland Energy GmbH. Upon revocation of the publication the certificate loses its validity. After the expiration of the certificate and on request of TÜV Rheinland Energy GmbH this document shall be returned and the certificate mark must no longer be used.

The relevant version of this certificate and its expiration date are also accessible on the internet at **qal1.de**.

Document history

Certification of the MT100 measuring system is based on the documents listed below and the regular, continuous surveillance of the manufacturer's quality management system:

Initial certification according to EN 15267

Certificate no. 0000074630_00: 03 September 2021 Expiry date of the certificate: 04 August 2026 Test report 936/21247922/A of 11 February 2021

TÜV Rheinland Energy GmbH, Cologne

Publication: BAnz AT 05.08.2021 B5, chap. I No. 1.1

UBA announcement dated 29 June 2021:



Certificate: 0000074630_00 / 03 September 2021



Calculation of overall uncertainty according to EN 14181 and EN 15267-3

| Measuring system Manufacturer AMS designation | Fluid (| | ents Internationa | I LLC. | | |
|---|--|----------|-------------------|----------------|--------------------|--|
| Serial number of units under test | 675808 / 675809 Thermal dispersion | | | | | |
| Measuring principle | | | | | | |
| Test report | 936/21247922/A | | | | | |
| Test laboratory | TÜV Rheinland | | | | | |
| Date of report | 2021-02-11 | | | | | |
| Measured component | Velocity | | | | | |
| Certification range | 0 - | 30 | m/s | | | |
| Evaluation of the cross-sensitivity (CS) (system with largest CS) | | | | | | |
| Sum of positive CS at zero point | | 0.00 | m/s | | | |
| Sum of negative CS at zero point | | 0.00 | m/s | | | |
| Sum of postive CS at span point | | 0.00 | m/s | | | |
| Sum of negative CS at span point | | 0.00 | m/s | | | |
| Maximum sum of cross-sensitivities | | 0.00 | m/s | | | |
| Uncertainty of cross-sensitivity | u _i | 0.000 | m/s | | | |
| Calculation of the combined standard uncertainty Tested parameter | | | | U ² | | |
| Standard deviation from paired measurements under field conditions * | u _D | 0.097 | m/s | 0.009 | (m/s) ² | |
| Lack of fit | u _D | 0.116 | | 0.013 | (m/s) ² | |
| Zero drift from field test | U _{d.z} | -0.052 | | 0.003 | (m/s) ² | |
| Span drift from field test | u _{d.s} | -0.121 | m/s | 0.015 | (m/s) ² | |
| Influence of ambient temperature at span | U _t | 0.100 | m/s | 0.010 | (m/s) ² | |
| Influence of supply voltage | u _v | 0.036 | m/s | 0.001 | (m/s) ² | |
| Cross-sensitivity (interference) | u _i | 0.000 | m/s | 0.000 | (m/s) ² | |
| Uncertainty of reference material at 70% of certification range | U _{rm} | 0.242 | m/s | 0.059 | (m/s) ² | |
| * The larger value is used: "Repeatability standard deviation at set point" or "Standard deviation from paired measurements under field conditions" | | | | | | |
| | | $\sum ($ | \2 | | | |
| Combined standard uncertainty (u _C) | $u_c = \sqrt{\sum \left(u_{\text{max, j}}\right)^2}$ | | ax, j) | 0.33 | | |
| Total expanded uncertainty | $U = u_0$ | * k = u | c * 1.96 | 0.65 | m/s | |
| | | | | | | |
| Relative total expanded uncertainty | U in % of the range 30 m/s | | | | 2.17 | |
| Requirement of 2010/75/EU | U in % of the range 30 m/s | | | | 7.84 ** | |
| Requirement of EN 15267-3 | U in % of the range 30 m/s | | | | 5.88 | |

^{**} The EU-directive 2010/75/EC on industrial emissions does not define requirements for this component. A value of 7.84 % was used instead.